



# CERTIFICATE

No. Z10 09 05 14312 009

**Holder of Certificate:** **Bachmann electronic GmbH**  
Kreuzäckerweg 33  
6800 Feldkirch  
AUSTRIA

**Factory(ies):** 14312

**Certification Mark:**



**Product:** Control units

**Model(s):** SLC284 / SDI208 / SDO204

**Parameters:**  
Rated input voltage: 24 VDC  
Operating temperature: -20°C...+60°C

**Tested according to:**  
IEC 61508:2000/EN 61508:2001 part 1 to 4 (SIL 3)  
IEC 62061:2005/EN 62061:2005 (SIL CL 3)  
IEC 61511-1:2003/EN61511-1:2004 (SIL 3)  
EN ISO 13849-1:2008 (Cat 4, PI e)  
EN 61131-2:2007

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** BF82595T

**Date,** 2009-06-15

Page 1 of 1

