



Product Service

# CERTIFICATE

No. Z10 14 12 62386 022

**Holder of Certificate:** Beckhoff Automation GmbH & Co. KG  
Hülshorstweg 20  
33415 Verl  
GERMANY

**Factory(ies):** 62386

**Certification Mark:**



**Product:** Safety components

**Model(s):** KL 2904, EL 2904

**Parameters:**

Supply voltage:	24VDC (-15%/+20%)
Power dissipation:	2W
Protection class:	IP 20

**Tested according to:**


- 2006/42/EC
- EN 61508-1:2010 (SIL 1-3)
- EN 61508-2:2010 (SIL 1-3)
- EN 61508-3:2010 (SIL 1-3)
- DIN EN ISO 13849-1:2008 (Cat 4, PL e)
- DIN EN 81-1:2000
- EN 13243:2004
- DIN EN 61000-6-2:2006
- DIN EN 61000-6-4:2007

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** BV82168T

**Valid until:** 2019-12-17

**Date,** 2014-12-18

  
( Günter Grell )



Page 1 of 1